

SUBMITTAL SHEET

**System 6100** Insulated Pipe & Equipment Sleeve

**CODE / STANDARDS**



Meets FHA and other U.S. government agency standards. Flame spread: not over 25. Smoke developed: not over 50.

**INSULATION**

R 4.2 1 1/4", fiberglass blanket,  
 R 6.0 1 1/4", fiberglass blanket  
 R 8.0 2 1/4", fiberglass blanket

**EXTERIOR FACING**

Metalized Scrim Reinforced Jacket

**THERMAL R-VALUE**

R 4.2 / R 6.0 / R 8.0

**VAPOR BARRIER PERMEANCE**

.05 Perm per ASTM - Method E96, Procedure A.

**TEMPERATURE RANGE**

-20° F to 250° F.

**SIZES IN DIAMETER**

4 / 5 / 6 / 7 / 8 / 9 / 10 / 11 / 12 / 14 / 16 / 18 / 20

**LENGTH IN FEET**

Standard 5ft; Custom 10ft

**INSIDE BEND RADIUS**

4 / 5 / 6 / 7 / 8 / 9 / 10 / 11 / 12 / 14 / 16 / 18 / 20



JOB _____	
LOCATION _____	JOB NO. _____
ENGINEER _____	JOB NO. _____
CONTRACTOR _____	REPRESENTATIVE _____
Certified Correct	
BY _____	BY _____
TITLE _____	TITLE _____
DATE _____	DATE _____

**Insulation Solution**

**Flexible Duct System**

**Metal Building Insulation**

(800) 837 - ANCO

2500 17<sup>th</sup> Street, Elkhart, Indiana 46517

[www.AncoProductsInc.com](http://www.AncoProductsInc.com)